
Test Report of the Manufacturer



Generated on 15.10.2007 by SSE

BI-METALLIC-CONNECTOR

BI-METALLIC-CONNECTOR

Part no.: BMC3SS



DEHN + SÖHNE
GmbH + Co KG

Hans Dehn-Str. 1
92318 Neumarkt
Germany

update: 2007-09-15

Type Test:: Test of the Lightning Current Carrying

Capability in accordance with EN 50164-1
DIN VDE 0185-201:2000-04



Component: BI-METALLIC-CONNECTOR Part No.: BMC3SS Ident.-No.: 0 Material: stainless steel	Tightening torque of the screws: 1.) M8 - 15 Nm 2.) M8 - 15 Nm
Test arrangement in accordance with EN 50164-1 Annex B	B02 B03 Connected conductor (1): round wire 8 aluminium Connected conductor (2): round wire 8 copper
Precondition/Ageing in accordance with Annexes C and D	Overground application C1 <input checked="" type="checkbox"/> C2 <input checked="" type="checkbox"/> Underground application D
Lightning current test in accordance with section 6.3	3 lightning current loads Class H <input checked="" type="checkbox"/> 100 kA (10/350)
Assessment after lightning current test in accordance with section 6.3	<input checked="" type="checkbox"/> passed Transient resistance: Specified value: $\leq 2,5 \text{ m}\Omega$
Releasing torque of the screws:	<input checked="" type="checkbox"/> passed
Visual check:	<input checked="" type="checkbox"/> passed
<p>Assessment: Thus, the device has passed the test in accordance with EN 50164-1-DIN VDE 0185-201:2000-04 and has been classified in class H.</p>	
_____ Test Engineer	_____ Test Engineer