


DEHNsupport Toolbox

DEHN Risk Tool - Brief Instructions




Program entry




1 Open project / customer management

Creating a Customer



Note:
The entered customer data
are also listed in the
printout

Creating a project




1 Highlight a customer

2 Create a project

3 Enter project data


Selecting the ground flash density



1 Open menu

2 Enter postal code

Selecting a calculation



1 Calculation

2 Risk calculation

Edit project data

Project data

Number	06/030
Name	Warehouse
Contact person	
Street	
Country	D
Postal code	92318
City	Neumarkt i.d.OPf., Stadt
Telephone 1	
Telephone 2	
Fax	
E-Mail	
Notes	

Basis of calculation

Standard	INT - IEC 62305
Version	IEC 62305-2:2010-12


Buttons: Apply, Cancel

1 Select a basis of calculation


2 Enter project data

3 Apply


Selection of the risks to be considered




Edit objects



Edit building dimensions



Building / basic data



1 Select the building type


2 Enter building dimensions

3 Apply



1 Define the relative location


Zones



1 Select classifications

2 Select and classify zones


Zones



1 Select properties

2 Describe the zone properties


Supply lines



- 1** Edit conductors
- 2** Add lines
- 3** Select lines
- 4** Apply



Supply lines



- 1** Select a line
- 2** Enter / select line parameters



Supply lines

Supply lines

Object: Warehouse

Supply lines: Power supply line

System connected

Characteristics of internal systems

Relative position of the connected system: Isolated object: No further objects in the vicinity

Risk:

R1 - Human life	R2 - Service to the public	R3 - Cultural heritage	R4 - Economic value
RT R1: 0 % 0,00E00 1E-5	RT R2: 0 % 0,00E00 0,001	RT R3: 0 % 0,00E00 0,0001	RT R4: 0 % 0,00E00 0,001

Basis of calculation: Standard: IEC 62305, Version: IEC 62305-2:2010



1 Describe the system connected, if any

Supply lines

Supply lines

Object: Warehouse

Supply lines: Telecommunication supply line

Characteristics of internal systems

LPZ 0B - Z1 outside of the building LPZ 1 - Z2 inside the building

Risk:

R1 - Human life	R2 - Service to the public	R3 - Cultural heritage	R4 - Economic value
RT R1: 0 % 0,00E00 1E-5	RT R2: 0 % 0,00E00 0,001	RT R3: 0 % 0,00E00 0,0001	RT R4: 0 % 0,00E00 0,001

Basis of calculation: Standard: IEC 62305, Version: IEC 62305-2:2010



1 Describe the characteristics of the internal systems in the zones

Properties

1 Select factors

2 Describe the properties of the zones

The screenshot shows the 'Properties' tab selected in the software interface. On the left, there is a sidebar with icons for Building, Zone, Supply line, Properties (which is selected), Losses, Costs, and Measures. The main area displays 'LPZ 08 - Z1 outside of the building LPZ 1 - Z2 inside the building'. It includes sections for Contact resistance, Soil / floor properties, Electric shock, Fire, and Risk. The Risk section shows values for R1-Human life (0 %, 0,00E00), R2-Service to the public (0 %, 1E-5), R3-Cultural heritage (0 %, 0,00E00), and R4-Economic value (0 %, 0,00E00). To the right, there is a 'Project data' panel with fields for Number (06/030), Name (Warehouse), Street (D), Country (92318), City (Neumarkt i.d.OPf.), Telephone 1, Telephone 2, Fax, E-Mail, Notes, and a 'Ground flash density Ng' field set to 1,43. Below that is a 'Basis of calculation' section with Standard (INT - IEC 62305) and Version (IEC 62305-2:2010).

Properties

1 Select shielding

2 Describe shielding

The screenshot shows the 'Properties' tab selected in the software interface. On the left, there is a sidebar with icons for Building, Zone, Supply line, Properties (selected), Losses, Costs, and Measures. The main area displays 'LPZ 08 - Z1 outside of the building LPZ 1 - Z2 inside the building'. It includes sections for Lightning protection system/equipotential bonding (all zones), Spatial shielding, and Internal spatial shielding. The Spatial shielding section shows 'External spatial shielding (all zones)' with 'No shielding' selected and 'KS1' set to 1. The Internal spatial shielding section shows 'No shielding' selected and 'KS2' set to 1. To the right, there is a 'Project data' panel with fields for Number (06/030), Name (Warehouse), Street (D), Country (92318), City (Neumarkt i.d.OPf.), Telephone 1, Telephone 2, Fax, E-Mail, Notes, and a 'Ground flash density Ng' field set to 1,43. Below that is a 'Basis of calculation' section with Standard (INT - IEC 62305) and Version (IEC 62305-2:2010).

Losses

DEHN Risk Tool 13/31 (2.047)

File Edit Language

Object Warehouse

Losses

L1 Human life L2 Services to the public L3 Cultural heritage L4 Economic value

LPZ 08 - Z1 outside of the building LPZ 1 - Z2 Inside the building

Factor for touch and step voltage
Typical value L1Lt 0,01

Factor for fire
Industrial, commercial L1Lf 0,02

Kind of special hazard
Average level of panic (e.g. structures designed for cultural or sport) L1hz 5

Damage factor for overvoltage
No loss L1Lo

Calculate additional loss
Presence of people in the dangerous place outside the structure. L1te hours/year
Persons injured outside the structure L1Life %

Risk

R1 - Human life		R2 - Service to the public		R3 - Cultural heritage		R4 - Economic value	
R1	1447 %	RT	0 %	RT	0 %	RT	0 %
1,45E-04	1E-5	0,00E00	0,001	0,00E00	0,0001	0,00E00	0,001

Project data Evaluation Results

Number 06/030
Name Warehouse
Contact person
Street
Country D
Postal code 92318
City Neumarkt i.d.OPf.,
Telephone 1
Telephone 2
Fax
E-Mail
Notes

Ground flash density Ng 1,43
Basis of calculation
Standard INT - IEC 62305
Version IEC 62305-2:2010

1 Select a type of loss

2 Select factors for losses in the zone

Costs

DEHN Risk Tool 13/31 (2.047)

A protected version of the object is required for this part of the program! (A protected version will now be automatically created.)

OK

1

File Edit Language

Object Warehouse

Losses

L1 Human life L2 Services to the public L3 Cultural heritage L4 Economic value

LPZ 08 - Z1 outside of the building LPZ 1 - Z2 Inside the building

Factor for touch and step voltage
No loss L1Lt 0

Factor for fire
Hospital, industry L1Lf 0

Damage factor for
Hospital, industry L1Lo 0

Calculate additional loss
Total value of goods in dangerous place outside the structure. L4ce USD
Value of all goods damaged outside the structure L4fe %

Risk

R1 - Human life		R2 - Service to the public		R3 - Cultural heritage		R4 - Economic value	
R1	1447 %	RT	0 %	RT	0 %	RT	1928 %
1,45E-04	1E-5	0,00E00	0,001	0,00E00	0,0001	1,93E-02	0,001

Project data Evaluation Results

Number 06/030
Name Warehouse
Contact person
Street
Country D
Postal code 92318
City Neumarkt i.d.OPf.,
Telephone 1
Telephone 2
Fax
E-Mail
Notes

Ground flash density Ng 1,43
Basis of calculation
Standard INT - IEC 62305
Version IEC 62305-2:2010

1 Confirm

Cost estimation

The screenshot shows the 'Cost estimation' dialog box for an object named 'Warehouse'. The top section displays rates: Interest rates (i) at 4,00 %, Maintenance rates (m) at 1,00 %, Amortization time (at) at 20 years, and Amortization rates (a) at 5,00 %. Below these are values for animals, building, content, internal systems, total structure value, and total loss costs. The bottom section, titled 'Warehouse protected', shows costs for protection measures (CP), total loss with protection (CRL), annual protection costs (CPM), and savings (S). A large blue number '1' is overlaid on the top rates section.

1 Enter rates



Measures

The screenshot shows the 'Select measures' dialog box. It includes a toolbar with icons for objects S1-S4 and an 'Edit objects' button. On the right, a 'Type of risk' dropdown is set to 'R.1 - Human life'. Below it are three tabs: 'Evaluation' (selected), 'Results', and 'Costs'. The 'Evaluation' tab displays three graphs for lightning protection zones: 'Ge' (General), 'LPZ OB - Z1 outside of the building', and 'LPZ 1 - Z2 inside the building'. A large blue number '1' is overlaid on the 'Ge' graph. The 'Results' tab contains sections for 'Power supply line' and 'Telecommunication supply line', both with connection and isolation conditions. The 'Costs' tab shows a risk bar chart for 'Risk' with categories RT and R, and numerical values 87 %, 8,71E-06, and 1E-5. A large blue number '2' is overlaid on the 'Power supply line' section, and a large blue number '3' is overlaid on the 'Costs' tab. A hand cursor icon is also present over the 'Evaluation' tab.

1 Select a type of risk

2 Select risk components according to the existing risk

3 Define protection measures



Measures

1 Select „Economic value“

2 Click „Evaluation“ tab

3 Select risk components according to the existing risk



Measures

1 Select zones

2 Define protection measures



Measures



Select measures

Object	Warehouse	RA	RB	RC	RM	RW	RV	RU	RZ
S1									
S2									
S3									
S4									

With protection/target state

Type of risk R4 - Economic value

Evaluation Results Costs

1 Click „Costs“ tab

2 Enter costs of protection measures

Costs of a total loss	CL	1.446.738 USD
Costs of protection measures	CP	25.000 USD
Costs of total loss with protection	CRL	20.759 USD
Annual costs of protection	CPM	0 USD
Savings	S	1.425.978 USD

